

Test Sheet: Electrical
Site:

Ecoelectric Pty Ltd
PO Box 218
Mount Ommaney
4074, QLD

Phone: +61 7 33766409
Fax: +61 7 33766407
E-mail: info@ecoelectric.com.au
Web: www.ecoelectric.com.au



Technician: Jeff Wehl

Date:
Location: MSB

| Test | Setting | Reading |
|-----------------------------------|------------------------------------|---------|
| Earth Continuity | Less than 0.5 Ohm | |
| Insulation | P1-P2 Insulation > 1Meg Ohm @ 500V | |
| | P1-P3 Insulation > 1Meg Ohm @ 500V | |
| | P1-N Insulation > 1Meg Ohm @ 500V | |
| | P1-E Insulation > 1Meg Ohm @ 500V | |
| | P2-P3 Insulation > 1Meg Ohm @ 500V | |
| | P2-N Insulation > 1Meg Ohm @ 500V | |
| | P2-E Insulation > 1Meg Ohm @ 500V | |
| | P3-N Insulation > 1Meg Ohm @ 500V | |
| P3-E Insulation > 1Meg Ohm @ 500V | | |
| Polarity & Volts Test | P1-N Volts | |
| | P2-N Volts | |
| | P3-N Volts | |
| | N-E Volts | |
| Phase Rotation | Phase | |
| Main Isolator Operation | N/A | |